

SIMPLIFIED WET ASH ARRESTING SYSTEM OPERATION AT DARYA KHAN SUGAR MILLS

Abdul Aziz Tahir

Technical Director, Darya Khan Sugar Mill

Email: abdulaziz@imporientgroup.com

ABSTRACT

There are number of techniques to combat the fly ash carryover with Boiler flue gas in Cane Sugar Industry. These are mainly dry Ash Collecting Cyclones, Wet Scrubbing, Electrostatic Precipitation and Wet Ash Arresting with Water Showing & Recycling. The Wet Ash Arresting System (WAAS) with water showering and recycling in a closed circuit, is the best ash arresting system for the Sugar Industry Boiler. The performance of the WAAS is improved if ash collection load is decreased with in-line installation of dry ash collecting cyclones system at primary stage. At Darya Khan Sugar Mills wet ash arresting system was installed with the erection of the boiler but it was not operative since long due to certain reasons. In off season 2018, major low cost modifications were made at site and system operated with success in season 2018-19. Full detail of modification, design, erection and operation of the system is discussed in the underlined paper.

Keywords: Wet ash, arresting system, processing, sugar mill.

INTRODUCTION

Darya Khan with 1st name as Adam Sugar Mills started its operation in 1976-77. In second Management group "Fecto Group" plant capacity was increased with addition of second mill tandem and Descon designed 80 tons, bi-drum, water tube, suspension grate furnace type Boiler. The boiler included fly ash arresting cyclones and wet ash arresting system. The ash arresting system included; concrete duct in between Induced Draft Fan and Boiler Chimney with fixed S.S spray mist nozzles installed in the top roof of concrete duct and ash collecting pit with spray water pump (Baikow, 1967). The installed system for ash arresting was not in operation since long due to certain reasons. In off season 2018 major low-cost modifications

were made at site and system operated with success in season 2018-19. The detail of modification, erection and operation work is discussed in detail in Material and Method section of the paper. Here is a review of some industrial applicable ash arresting techniques:

Fly Ash Collecting Cyclones

Application and Performance

The cyclone is widely used type of particulate collection device in which dust laden gas enters tangentially into a cylinder or conical chamber and leave through a central opening. The resulting vortex motion or spiraling gas flow pattern creates a strong centrifugal force filed in which dust particles, by virtue of

their inertia, separate from the carrier gas stream. The ash particles migrate along the cyclone walls by gas flow and gravity forces and ultimately fall into storage receiver in the bottom side of the cyclone. The particulates are composed of fly ash and un-burnt constitutes of Bagasse particles. Cyclones are installed to collect the coarse dust particulates (Hugot, 1986). In Cane Sugar Factory, this is mandatory dust collecting device installed at 1st stage, in line with other high efficiency dust collecting device installed at 2nd stage. The cyclones are made of cast steel to face abrasion forces of tangentially striking and sliding carbon particles. In Boiler installations, nos. of cyclone of 300 to 500 mm diameter of certain cone length are installed in parallel after the Air Pre-heater as per capacity

and design. The efficiency of cyclone depends upon the particle size, particle density, in-let gas velocity and cyclone body or cone length.

Advantages

The advantages of selecting cyclones over other particulate collecting devices are:

Have no moving part. Easy to install or replace. Minimum space requirement to place. Serve with wide range of flue gas temperature and pressure. Low capital cost and maintenance cost.

Disadvantages

The disadvantages of selecting cyclones over other particulate collecting devices are:

Have low collecting efficiency
Require dry condition for operation

Electrostatic Precipitators (ESP)

Application and Performance

An electrostatic precipitator is a device which removes particles from the flue gas stream. It accomplishes particle separation by the use of an electric field which imparts a positive or negative charge to the particle, attracts the particle to an oppositely charged plate or tube, removes the particles from the collection surface to a hopper by vibrating or rapping the collection surface (Khan, 2000). EPS are among the

most widely used particulate control devices, grading as highly efficient operation. ESP devices used to control particulate emission from electric utility industry and wide range of industrial boilers. Parallel plate EPS are commonly employed in the utility industry to control emission from coal fire boilers. These can place in cold and hot gas environments. Cold type as prevalent type because of most easily retrofitted in the design of new installations. An ESP can be used for fine particulate collection at Bagasse fired boiler installation if precaution is taken for fire prevention. The EPS is 2nd stage mounting device, preceded by some mechanical type dust particulate collecting device to prevent hot glowing massive char from entering the precipitates and possible starting fire.

Advantages

The pressure drop through precipitator is a function of inlet and outlet design and precipitator length. The pressure drop rarely exceeds 0.5 inch of WG. The ESP can be designed to have 99.9 + % collection efficiency. Silicon control rectifiers and other modern control devices allow an EPS to operate automatically. Have low maintenance cost.

Disadvantages

The formation of acid dew point during frequent start, stop operations, can cause

structural damage and allow flue gas leakage. An ESP is sensitive to its design parameters, changing the type and nature of fuel could drastically affect its performance.

High capital cost. High Voltage are required for operation. Could control only discharge of carbon particulate which can bear electric charge.

Wet Scrubbers

The Scrubber utilizes a liquid to separate particulates or other gaseous contamination from flue gas. The separation is achieved from mass contact of the liquid and gas. These can control Boiler emission including fly ash and Sulphur oxides. Many types of Wet scrubbers are employed for controlling boiler gas contamination as per requirement of use of friction of clean gas for secondary purpose or discharge to atmosphere. We will discuss only two type wet scrubbing units for application in Sugar Industry.

Plate type Scrubber

A Plate type scrubber consists of hallow type cylinder with multi number of perforated plates mounted transversely in the tower. Gas comes from the bottom of the tower passes through the perforation while liquid water introduces from the top and passes over the tray left to right then on next bottom plate right to left to provide sealing to gas flow. Dirt

particles, while moving gas, trap with liquid sealing, causing mass transfer from gas to liquid. Gas while passing through the number of plates, as designed, get clean before the exit from the tower. The dust/ impurities entrapped with liquid, flow with it exit from the bottom.

Wet Scrubber using showering and recycling water

This type of unit is utilized for scrubbing fraction of gas stream for some other purpose. On large scale, number of special designed nozzles is fixed at the top of the enclosed channel/duct normally made of concrete. The water is sprayed from these nozzles and gas enter at one end of the duct at 90 degree to the flow of water from these nozzles and exit from another end. The velocity of discharge water and mix flow pattern of nozzle entraps the dust particles which discharge with dirty water leaving from the channel.

Advantages

The efficiency of wet scrubber is good for entrapping the particles larger than several microns in diameter. Pressure drops range from 1 to 6 in WG. Once build concrete unit last longer life without maintenance. The spray water is recycled with fractional addition of fresh water against lost with gas.

Disadvantages

Gas passing through the water spray, drops its temperature and make it moist. The specific weight of the gas increased causing load at ID fan drive. The wet gas become acidic in nature due to reaction of spray water with CO₂ and cause damages to the mild steel chimney and spray nozzles.

MATERIAL AND METHOD

The Ash arresting System made with erection of the 80 Tons Boiler, included concrete duct, S.S mist spray nozzles

fixed at the roof top, dirty water pit and recycling water pump (Rein, 2007).



Following modifications were made at site:

Blocked all the nozzles except 5 nos. at the top roof of the concrete duct.

Installed the top deflection plate and water spray header. Installed the angle deflection plate and water spray header. calculated the x-area of ID Fan outlet steel duct and reduce the concrete duct x-section area accordingly with brick and cement lining.

Made 600 mm off center the gutter from the bottom of the top plate toward chimney to provide extra surface area for free falling the entrapped ash particles on angle plate.

The ash pit as shown in Sketch #5, modified to increase the flow length of the dirty water for natural separation and settling of dust particles from the main stream of dirty water.



sketch # 5, is made of red bricks coated with cement layer. The dirty water passes through 3 channels of width 1472mm, depth 1192 mm and length of 10035 mm.

The dead slow speed of dirty water forced the gravity settling of dust particles in the bottom of the pit channels. At the last end of the 3rd channel water collection pit is made, where lift pump of 150 m³/hr

capacity of 20-meter head is installed to recycle the “clean” pit water to gas arresting system. The clean pit water is recycled through the both deflection plate headers.

The settled ash in the pit is manually evacuated as per demand. In 1st running season of 89 days length, the pit was cleaned once at the end of the season.

The Type and Water Quantity:

Water type

The water from overhead water service tank is sprayed through the roof top fixed mist nozzles.

The clean pit water is sprayed and recycled through the both deflection plate headers.

Water Quantity

I	Overhead tank water for mist nozzles	0.7 tons/hr
li	Sprayed through top header of top deflection plate	44.0 tons/hr
lii	Sprayed through top header of angle deflection plate	45.0 tons/hr
Total water quantity for the System		89.7 tons/hr, 89700 kg/hr

The overhead water flow through top roof fixed nozzles, serve as make up water for the system. The recycling water can also make up through fresh water connection in the suction pit of the recycling water pump. The surplus water from the system can also out flow through pit pump delivery.

Operation of the Ash Arresting System

All the modification/ erection work was completed in the offseason 2018. The system was put in operation at the start of the season 2018-19. Except minor adjustments in quantity of spraying and recycling water during trial run, nothing was done during operation for the Boiler for entire length of season 2018-19. The exit gas from the Boiler chimney turned to

contamination free white vapors as showed in Pic # 1. Mill colony residents and surround area residents showed happiness on the operation of the Ash Arresting System at 80 tons Boiler. About 5 % increase in load was observed for ID Fan drive due to the density increase of gas as carrying water vapors.

Inner inspections of the system duct were made during stop operation of Boiler due to Milling shut down for various reasons.

Flue Gas and Spraying Water Ratio

Referring to the Table No.2, 1 kg Bagasse on combustion produce 3.3129 m³ of flue gas with 23.7 % excess air. For semi auto operation of the boiler control at Darya Khan, we take 5 % excess volume

of gas, which makes it 3.478 m³ per kg of Bagasse. Taking 1 ton Bagasse consumption to produce 2.2 tons steam of 25 bar and 350°C at Boiler. At average load of 76 tons per hr, the Boiler consumed 34.55 tons/hr Bagasse and produced 120165 m³ gas per hr. The ratio of gas to spraying water: $120165/89700 = 1.34$ m³ gas /kg water.

RESULTS AND DISCUSSION

The Environment Protection Agency Pakistan (EPA) set the standard of 500 mg/Nm³ for maximum particulate carry with Boiler flue gas. As Bagasse has minimum level of Sulphur of 0.05 %, So So₂ gas percentage in flue gas of Bagasse fired boiler is not a issue of EPA.

The Wet Ash Arresting System was installed in off season 2018 and operated with excellent performance in season 2018-19. No technical and human right issue was raised throughout the season as emitted gas from Boiler chimney turned to water vapors as shown in Pic #1. In crushing season 2017-18, EPA experts tested the smoke

sample of 80 tons Boiler of DKSM and raised no complaint, whereas the Boiler was operated with only cyclone ash arresting system. In crushing season 2018-19, DKSM installed and operate Wet Ash Arresting System, EPA raised no complaint against DKSM.

Author also acknowledges the assistance and dedicated efforts of Mushtaq Ali Shad, Technical Manager, Safdar Hussain Shah, Chief Engr. (Boiler) and Saqib Saeed Saadi, Sr. Engr. for the design, erection and operation of the system.

ACKNOWLEDGEMENT

REFERENCES

- Baikow, V.E., 1967. Manufacturing and refining of raw cane sugar. Elsevier publishing company, New York.
- Hugot, E., 1986. Handbook of sugarcane engineering. Saint-Denis (Re-Union).
- Khan, H. R., 2000. Fabrication Practices of Boiling House of a sugar Factory. Karachi, Pakistan. 62-63.
- Rein, P.W., 2007. Cane Sugar Engineering. Verlag Dr. Albert Bartens KG, Berlin, Germany page 455-465.